



### COMPONENT CODE

BC BLOWER CONTACTOR  
 CC COMPRESSOR CONTACTOR  
 CCH CRANKCASE HEATER  
 COMP COMPRESSOR  
 CT CONTROL TRANSFORMER  
 DISC DISCONNECT SWITCH  
 FLMS FLAME SENSOR  
 FT FREEZE STAT  
 GFCD GROUND FAULT CONVENIENCE OUTLET  
 GL GROUND LUG  
 GND GROUND  
 GV GAS VALVE  
 HPC HIGH PRESSURE CONTROL  
 IBM INDOOR BLOWER MOTOR BELT DRIVE  
 IDM INDUCED DRAFT MOTOR  
 IFC INTEGRATED FURNACE CONTROL

LAC LOW AMBIENT COOLING CONTROL  
 LC LIMIT CONTROL  
 LPC LOW PRESSURE CONTROL  
 COMPRESSOR  
 MAS MIX AIR SENSOR  
 MRLC MANUAL RESET LIMIT CONTROL  
 NPC NEGATIVE PRESSURE CONTROL  
 OFM OUTDOOR FAN MOTOR  
 PCB PRESSURE CONTROL BOARD  
 PL PLUG  
 RC RUN CAPACITOR  
 SE SPARK ELECTRODE  
 TB TERMINAL BLOCK  
 WIRE NUT

### WIRING INFORMATION

LINE VOLTAGE  
 -FACTORY STANDARD \_\_\_\_\_  
 -FACTORY OPTION - - - - -  
 -FIELD INSTALLED .....

LOW VOLTAGE  
 -FACTORY STANDARD \_\_\_\_\_  
 -FACTORY OPTION - - - - -  
 -FIELD INSTALLED .....

REPLACEMENT WIRE  
 -MUST BE THE SAME SIZE AND TYPE OF INSULATION AS ORIGINAL (105 C°MIN.)

WARNING  
 -CABINET MUST BE PERMANENTLY GROUNDED AND CONFORM TO I.E.C., N.E.C., C.E.C. AND LOCAL CODES AS APPLICABLE.

### WIRE COLOR CODE

BK	BLACK	O	ORANGE
BR	BROWN	PR	PURPLE
BL	BLUE	R	RED
G	GREEN	W	WHITE
GY	GRAY	Y	YELLOW

### WIRING DIAGRAM

(-)/LKL/LNL-B151

208-230/460/575V 3 PH, 60 HZ.

200-220/380-415V, 3 PH, 50HZ

DR. BY	APP. BY	DATE	DWG. NO.	REV
MGR		8-14-12	90-102892-05	01